

Forest View Acres Water District

Operations Report – August 28, 2008

Prepared by Erik Tamer, Southwest Water Co.

Sampling:

- The July Coliform sample result was acceptable.
- Samples were collected for TTHM/HAA5 (quarterly) and VOC for the SWTP.
- Water Quality samples were also collected for the Corrosion Control Study

Treatment Plants:

Arapahoe Water Plant:

- The plant is operating normally.

Transmission Line/Booster Station:

- The 20HP booster pump failed some time during the night of Sat. Aug. 16th. AmWest made a service call and determined the soft-start had failed. A proposal for replacement has been provided.

Surface Water Plant:

- The plant has been off-line since August 1st. Recent rains, however will now allow us to restart the plant. Further evaluation of water levels at the creek inlet will be conducted weekly during plant operation.
- The leaking raw water line above the plant has been repaired. The white 2" pvc pipe above our line was determined to be the old feed line to ponds in the district.

Distribution system:

- The final of the 6 old PRVs was reconditioned on Aug. 21st. In addition, gages were installed on the new 8" PRV near the intersection of Redstone Ridge Rd. and Pixie Park. All reconditioned valves appear to be operating normally and have been adjusted to the set points established by a previous operator. A survey of fire hydrant pressures has been started and will continue.
- The valves in the street on Shilo Pines Dr. were straightened, vacuumed out, raised to grade, and asphalted in.
- The fire hydrant in front of 17475 Oxbridge Rd. was repaired on Aug. 21st with the help of Gary McMillin from Dana Kepner Co. in Denver.

Miscellaneous:

- The meter pit for the Pollonco residence has been partially installed. At this point, the meter is in, but a remote register cannot be installed until the pit is backfilled.